

66'

Fire Chiefs Association

FIRE PREVENTION OFFICERS SECTION

Santa Cruz County

DATE:
06/06/02

APPROVED:
M. Biddle SCO

TITLE: Turnarounds
(outside Urban Service Line)

FIRE PREVENTION STANDARDS

Cul-de-sac Circular Driveway 16' Radius 36' RADIUS 36' Radius Any Width over 12' Any Width over 12' Lateral Slip Hammer - Head 20' Radius 16' Minimum Same Width as Driveway or Road 51' Minimum 20' Radius 35' Minimum 35' Minimum 16' Minimum 33' to 39'

ALL CONFIGURATIONS SHALL BE UNOBSTRUCTED (NO PARKING) AND ALL MINIMUM DISTANCES AND WIDTHS SHALL BE MAINTAINED